SatisfactorySUnsatisfactoryXCommentCNot In ServiceN/SNot ApplicableN/A

Structure Overall Condition

	Calibration Due:
Product Supply Pressure Gauge 1	Calibration Due:
Product Supply Pressure Gauge 2 Grounding Connections, Static Reels,	Calibration due:
Cables, and Clamps	Calibration Due:
LC Mass Flow Meter	
Mass Flow Control Valve	
Top Tech Multiload System Controller	Calibration Due (Mass Meter Calibration):
Meter Digital Display Board	
APU Leak Test Flow Indicator/Meter	Calibration Due:
Engine Leak Test Flow Indicator/Meter	Calibration Due:
Flush Pump	
Differential Pressure Indicator (Flush	
Pump)	
Emergency Stop Switch (s)	
Underwing Aircraft Nozzle Filter/Screen-	M=Monthly/Q= Quarterly/A=Annually (M)
Clean/Inspect	(IVI)
Overwing Aircraft Fueling Nozzle Filter/Screen-Clean/Inspect	(M)
APU Engine Leak Test/ Flush Hose 1 Filter	(M)
(GTP-8923)-Clean/Inspect APU Engine Leak Test/ Flush Hose 2 Filter	
(GTP-8923) Clean/Inspect	(M)
Flush Pump Filter (Norman 535A-10RL)	(Q) Recorded DP(PSI)
Flush Pump Inlet Strainer- Clean/Inspect	(M)
	(M)
Flush PumpVerify Operation APU Leak Test Pump Air Filter-	(M)
Clean/Inspect	
APU Leak Test Pump Air Supply Oiler- Verify/Fill	(M)
APU Leak Test PumpVerify Operation	(M)
Engine Leak Test Pump Air Filter-	(M)
Clean/Inspect Engine Leak Test Pump Air Supply Oiler-	(M)
Verify/Fill	
Engine Leak Test PumpVerify Operation	(M)
Expansion Tank Pressure-Check/Record	(M) Pressure Reading (PSI)
	(M)
Hose Reels-Lubrication Points- Grease ALL	(M)
Flush Pump Lubrication Points-Grease	(M)
Pump Coupling Inspection	
Fuel Delivery Header- Manual Air Purge	(M)
Grounding Points- Clean/Measure Resistance	Resistance Reading (Ohms) Due:
	(M)
Deadman Control-Test	(M)
Emergency Stop Switch-Test	(M)
Inspection Date Label Replacement-ALL	(IVI)
Signature:	
orginatur c.	

Print:	
Date [.]	